

CERTIFICATE OF COMPLIANCE

Certificate Number 20141021-E183151
Report Reference E183151-20140930
Issue Date 2014-OCTOBER-21

Issued to: PROSOFT TECHNOLOGY INC
5201 Truxtun Ave 3
Bakersfield CA 93309-0421

**This is to certify that
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS

Programmable Controllers for use in Hazardous Locations,
Class I, Div. 2, Groups A, B, C, and D.

Open Type Communication Module: Models ILX69-PBM
and ILX69-PBS. May be marked with suffix "-cc" indicating
conformal coating.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for
Use in Class I and II, Division 2 and Class III, Divisions 1
and 2 Hazardous (Classified) Locations
CSA C22.2 No. 213, Non-incendive Electrical Equipment for
Use in Class I, Division 2 Hazardous Locations
UL 508, Industrial Control Equipment
CSA C22.2 No. 142, Process Control Equipment

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

